

Annual
Water
Quality
Report
Reporting Year 2015



Presented By
Gadsden Water Works & Sewer Board
PWS ID#: AL0000577

Meeting the Challenge

We are once again proud to present our annual water quality report covering all testing performed between January 1 and December 31, 2015. Over the years we have dedicated ourselves to producing drinking water that meets all state and federal standards. We continually strive to adopt new methods for delivering the best quality drinking water to you. As new challenges to drinking water safety emerge, we remain vigilant in meeting the goals of source water protection, water conservation, and community education while continuing to serve the needs of all our water users. Please share with us your thoughts or concerns about the information in this report. After all, well informed customers are our best allies.

Conclusion of Source Water Assessment

The susceptibility analysis identified several contaminant sources that potentially could affect the quality of the source water, as well as affect the operation of the C. B. Collier Water Treatment Plant. To help address these concerns, the GWWSB developed its Contingency Plan. In addition, the GWWSB monitors numerous sampling points around the lake each month. These data are used to track the water quality in the lake and to identify contaminant sources. These data will continue to be gathered and used for monitoring contamination to the lake. The GWWSB realizes that protection of its water resources is an important part of providing high-quality drinking water to our community. In an effort to protect our drinking water source, the GWWSB is an active member of the Coosa River Basin Clean Water Partnership, a group dedicated to protecting and restoring water quality and biological integrity in the Coosa River Basin.

Source Water Description

The Gadsden Water Works' customers are fortunate because we enjoy an abundant water supply from the Coosa River. Our water source comes from the Basin called the Middle Coosa. This watershed contains 23 rivers and streams. There are 420 lakes in the watershed, for a total of 31,285.7 acres of surface area. There are approximately 3,359.6 total river miles in this basin. The basin is fed from the Upper Coosa Basin and multiple aquifers, including Pennsylvanian aquifers, Valley and Ridge aquifers, and Valley and Ridge carbonate-rock aquifers. All of the sources provide approximately 3.4 billion gallons average flow through the Gadsden area. From this source, our water treatment facilities can currently produce up to 24 million gallons of clean drinking water every day for the City of Gadsden and surrounding water distribution systems. To learn more about our watershed on the Internet, go to http://cfpub.epa.gov/surf/huc.cfm?huc_code=03150106.

Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791 or <http://water.epa.gov/drink/hotline>.

Lead in Home Plumbing

As required by federal and state agencies, the GWWSB has an outside laboratory monitor samples collected in our distribution system for lead. Lead levels in our system have always been well below the minimum standard. Even though we do not have a problem with lead, the following information about lead is required in this report: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for thirty (30) seconds to two (2) minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Interesting and Useful Water Facts

Roughly 70% of an adult's body is made up of water.

Water dissolves more substances than any other liquid. Wherever it travels, water carries chemicals, minerals, and nutrients with it.

The United States uses nearly 80 percent of its water for irrigation and thermoelectric power.

The average person in the United States uses between 80 and 100 gallons of water per day.

By the time a person feels thirsty, his or her body has lost over one percent of its total water amount.

One gallon of water weighs 8.34 pounds.

One inch of water covering one acre of land would equal 27,152 gallons and would weigh 113 tons.

Substances That Could Be in Water

In order to ensure that tap water is safe to drink, the U.S. EPA prescribes regulations limiting the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and it can pick up substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:

Microbial Contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, or wildlife;

Inorganic Contaminants, such as salts and metals, which can be naturally occurring or may result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

Pesticides and Herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;

Organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and may also come from gas stations, urban stormwater runoff, and septic systems;

Radioactive Contaminants, which can be naturally occurring or may be the result of oil and gas production and mining activities. For more information about contaminants and potential health effects, call the U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791.

Community Participation

You are invited to participate in our public forum and voice your concerns about your drinking water. We meet the third Monday of each month beginning at 4 p.m. in the boardroom at the Administration Building, 515 Albert Rains Blvd., Gadsden, AL.

Questions?

For more information about this report, or for any questions relating to your drinking water, please call Chad Hare, General Manager, at (256) 543-2884, ext. 222.

Sampling Results

During the past year, we have taken hundreds of water samples in order to determine the presence of any radioactive, biological, inorganic, volatile organic, or synthetic organic contaminants. The tables below show only those contaminants that were detected in the water. The state requires us to monitor for certain substances less often than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken. Based on a study conducted by ADEM with the approval of the EPA, a statewide waiver for the monitoring of asbestos and dioxin was issued; thus, monitoring for these contaminants was not required.

REGULATED SUBSTANCES							
SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCL [MRDL]	MCLG [MRDLG]	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	TYPICAL SOURCE
Chlorine (ppm)	2015	[4]	[4]	2.20	0.20 - 2.20	No	Water additive used to control microbes
Fecal coliform and E. coli (# positive samples)	2015	0	0	0	NA	No	Human and animal fecal waste
Fluoride (ppm)	2015	4	4	0.64	0.40 - 1.10	No	Erosion of natural deposits; Water additive that promotes strong teeth; Discharge from fertilizer and aluminum factories
Haloacetic Acids [HAAs] (ppb)	2015	60	NA	9.19	3.04 - 20.90	No	By-product of drinking water disinfection
Nitrate (ppm)	2015	10	10	0.16	NA	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
TTHMs [Total Trihalomethanes] (ppb)	2015	80	NA	22.25	7.21 - 48.90	No	By-product of drinking water disinfection
Total Coliform Bacteria (% positive samples)	2015	5% of monthly samples are positive	0	0	NA	No	Naturally present in the environment
Total Organic Carbon (ppm)	2015	TT	NA	0.84	0.56 - 1.31	No	Naturally present in the environment
Turbidity ₁ (NTU)	2015	TT	NA	0.059	0.028 - 0.185	No	Soil runoff
Turbidity (Lowest monthly percent of samples meeting limit)	2015	TT	NA	100	NA	No	Soil runoff

₁ Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system.

Substance (Unit of Measure)	Year Sampled	Amount			Sites Above		Typical Source
		AL	MCLG	(90th%tile) Detected	AL/Total Sites	Violations	
Copper (ppm)	2015	1.3	1.3	0.196	0/30	No	Corrosion of household plumbing systems; Erosion of natural deposits
Lead (ppb)	2015	15	0	<5	0/30	No	Corrosion of household plumbing systems; Erosion of natural deposits

Tap water samples were collected from 30 sample sites throughout the community for lead & copper analyses.

SECONDARY SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT			RANGE LOW-HIGH	VIOLA- TION	TYPICAL SOURCE
		SMCL	MCLG	DETECTED			
Chloride (ppm)	2015	250	NA	30.1	NA	No	Runoff/leaching from natural deposits
Color (Units)	2015	15	NA	3.3	3.00 - 13.00	No	Naturally occurring organic materials
Iron (ppm)	2015	300	NA	0.011	0.01 - 0.02	No	Leaching from natural deposits; Industrial wastes
Manganese (ppm)	2015	50	NA	0.016	0.005 - 0.041	No	Leaching from natural deposits
pH (Units)	2014	6.5-8.5	NA	7.64	7.4 - 8.5	No	Naturally occurring
Sulfate (ppm)	2015	250	NA	16.0	NA	No	Runoff/leaching from natural deposits; Industrial wastes
Total Dissolved Solids [TDS] (ppm)	2015	500	NA	116	NA	No	Runoff/leaching from natural deposits
Zinc (ppm)	2015	5	NA	0.089	NA	No	Runoff/leaching from natural deposits; Industrial wastes

UNREGULATED SUBSTANCES

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AMOUNT		RANGE LOW-HIGH	TYPICAL SOURCE
		DETECTED	AMOUNT		
Bromodichloromethane (ppb)	2015	7.22	2.73- 15.20	By-product of drinking water disinfection	
Chlorodibromomethane (ppb)	2015	4.34	1.51 - 8.82	By-product of drinking water disinfection	
Chloroform (ppb)	2015	10.43	2.45 - 23.60	By-product of drinking water disinfection	
Sodium (ppm)	2015	16.9	NA	Naturally occurring	
Sulfate (ppm)	2015	16.0	NA	Naturally occurring	

**UNREGULATED CONTAMINANT MONITORING LISTS/RESULTS
DETECTED DURING UCMR3 TESTING (Four Samples)**

Analyte	Average	Range	Units
Chromium-6	0.15	0.13 - 0.22	ppb
Chromium-Total	0.13	ND - 0.3	ppb
Cobalt	ND	ND	ppb
Molybdenum	ND	ND	ppb
Strontium	56	43 - 68	ppb
Vanadium	0.4	ND - 0.8	ppb
1,1-dichloroethane	ND	ND	ppb
1,2,3-trichloropropane	ND	ND	ppb
1,3-butadiene	ND	ND	ppb
bromochloromethane	ND	ND	ppb
bromomethane	ND	ND	ppb
chlorodifluoromethane	ND	ND	ppb
chloromethane	ND	ND	ppb
1,4-dioxane	0.10	0.10 - 0.11	ppb
perfluorobutane sulfonic acid	ND	ND	ppb
perfluoroheptanoic acid	0.02	0.01 - 0.03	ppb
perfluorohexane sulfonic acid	ND	ND	ppb
perfluorononanoic acid	ND	ND	ppb
perfluorooctanoic acid	0.03	0.02 - 0.04	ppb
perfluorooctane sulfonic acid	0.04	ND - 0.05	ppb
chlorate	ND	ND	ppb

ND = Not Detected; ppb = parts per billion

Definitions

AL (Action Level): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

MCL (Maximum Contaminant Level): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MCLG (Maximum Contaminant Level Goal): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MRDL (Maximum Residual Disinfectant Level): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

MRDLG (Maximum Residual Disinfectant Level Goal): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

NA: Not applicable

NTU (Nephelometric Turbidity Units): Measurement of the clarity, or turbidity, of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

ppb (parts per billion): One part substance per billion parts water (or micrograms per liter).

ppm (parts per million): One part substance per million parts water (or milligrams per liter).

TT (Treatment Technique): A required process intended to reduce the level of a contaminant in drinking water.

The following substances were tested for in 2015 and not detected in our drinking water:

1-Trichloroethane, 1,1,2-Trichloroethane, 1,1-Dichloroethylene, 1,2,4-Trichlorobenzene, 1,2-Dichloroethane, 1,2-Dichloropropane, Benzene, Carbon Tetrachloride, Cis-1,2-Dichloroethylene, Ethylbenzene, Methylene Chloride (Dichloromethane), Monochlorobenzene, o-Dichlorobenzene, p-Dichlorobenzene, Styrene, TCE (Trichloroethylene), Tetrachloroethylene, Toluene, Trans-1,2-Dichloroethylene, Vinyl Chloride, Xylenes, 1,1-Dichloropropene, 1,1,1,2-Tetrachloroethane, 1,1,2,2-Tetrachloroethane, 1,1-Dichloroethane, 1,2,3-Trichlorobenzene, 1,2,3-Trichloropropane, 1,2,4-Trimethylbenzene, 1,3-Dichloropropane, 1,3-Dichloropropene, 1,3,5-Trimethylbenzene, 2,2-Dichloropropane, Bromobenzene, Bromochloromethane, Bromoform, Bromomethane, Chloroethane, Chloromethane, Dibromomethane, Dichlorodifluoromethane, Hexachlorobutadiene, Isopropylbenzene, M-Dichlorobenzene, Methyl-Tertiary Butyl Ether (MTBE), N-Butylbenzene, Naphthalene, N-Propylbenzene, o-Chlorotoluene, p-Chlorotoluene, p-Isopropyltoluene, Sec-Butylbenzene, Tert-Butylbenzene, Trichlorofluoromethane, Antimony, Arsenic, Barium, Beryllium, Cadmium, Chromium, Cyanide, Lead, Mercury, Nickel, Nitrite, Selenium, Thallium, Foaming Agents (Surfactants), Silver, Monobromoacetic Acid, Regulated Synthetic Organic Chemicals (SOCs)

Anyone interested in the detection limits and/or analytical information in general should contact Guy Posey at (256) 543-2884, ext. 212, or send an email message to gposey@gadsdenwater.org

Water Main Flushing

Distribution mains (pipes) convey water to homes, businesses, and hydrants in your neighborhood. The water entering distribution mains is of very high quality; however, water quality can deteriorate in areas of the distribution mains over time. Water main flushing is the process of cleaning the interior of water distribution mains by sending a rapid flow of water through the mains.

Flushing maintains water quality in several ways. For example, flushing removes sediments like iron and manganese. Although iron and manganese do not pose health concerns, they can affect the taste, clarity, and color of the water. Additionally, sediments can shield microorganisms from the disinfecting power of chlorine, contributing to the growth of microorganisms within distribution mains. Flushing helps remove stale water and ensures the presence of fresh water with sufficient dissolved oxygen, disinfectant levels, and an acceptable taste and smell.

During flushing operations in your neighborhood, some short-term deterioration of water quality, though uncommon, is possible. You should avoid tap water for household uses at that time. If you do use the tap, allow your cold water to run for a few minutes at full velocity before use and avoid using hot water, to prevent sediment accumulation in your hot water tank. Please contact us if you have any questions or if you would like more information on our water main flushing schedule.

Things You Can Do to Help

Make sure the plumbing system in your home or business is in good repair and proper working order. Lead pipes and lead solder should not be used. The lead from these can leach into your home. Have all leaks repaired to prevent wasting of water.

City code requires that all customers have a check valve on their water service line to prevent water in your system from running back into the public system. Section 606.1 of the International Plumbing Code requires each dwelling or business have a customer-owned water isolation valve.

City Ordinance 16-45 requires that all customers connected to the sanitary sewer system have a backup valve on their sewer lateral to prevent sewage from backing up into their residence in the event of a main line surcharge or blockage. The Water Works and Sewer Board of the City of Gadsden assumes no liability for any damage which may occur due to the absence or malfunction of this valve.

What Causes the Pink Stain on Bathroom Fixtures?

The reddish-pink color frequently noted in bathrooms on shower stalls, tubs, tile, toilets, sinks, toothbrush holders, and on pets' water bowls is caused by the growth of the bacterium *Serratia marcesens*. *Serratia* is commonly isolated from soil, water, plants, insects, and vertebrates (including man). The bacteria can be introduced into the house through any of the above mentioned sources. The bathroom provides a perfect environment (moist and warm) for bacteria to thrive. The best solution to this problem is to continually clean and dry the involved surfaces to keep them free from bacteria. Chlorine-based compounds work best, but keep in mind that abrasive cleaners may scratch fixtures, making them more susceptible to bacterial growth. Chlorine bleach can be used periodically to disinfect the toilet and help to eliminate the occurrence of the pink residue. Keeping bathtubs and sinks wiped down using a solution that contains chlorine will also help to minimize its occurrence. *Serratia* will not survive in chlorinated drinking water.

Contacts: Phone: 256-543-2884 Fax: 256-543-7704
Chad Hare, General Manager 256-543-2884 ext. 222
Guy Posey, Supt. of Water Treatment & Production ext. 212
www.gadsdenwater.org